



Sarah Huckabee Sanders
GOVERNOR

Renee Mallory
SECRETARY OF HEALTH

Jennifer Dillaha
DIRECTOR

June 15, 2026

Julia Thomas
Lewis Architects Engineers
11225 Huron Ln Ste 104
Little Rock, AR 72211
mlynch@lemvrw.com

RE: Project # 144470
Bryant First Baptist Church
6715 Hwy 5 N
Bryant, AR 72022

The plans and specifications for the above-mentioned project have been reviewed and approved by the Plumbing and Natural Gas Section of the Arkansas Department of Health. No deviations from the accepted plans, specifications, and/or addenda will be permitted during construction except by prior written acceptance. This approval is valid for one (1) year from the date on this letter or this acceptance must be re-validated by contacting this office with reference to the above reference file numbers. **Note:** Plans & specifications will be discarded after completion of the review and in no case will the file be retained for more than a six (6) month period.

This letter is for the **plumbing portion of this project only**. The architect, engineer, designer, or agent of the owner shall provide all contractors with a copy of this letter. Swimming pools, public water/sewer extensions, fire protection systems, sewage disposal systems, and water wells are regulated by other sections of the Arkansas Department of Health and are subject to plan review approval before construction begins. For more information about food service requirements, please contact Environmental Health Protection at (501) 661-2171.

All plumbing and gas work shall meet minimum state plumbing code standards and be performed by a duly licensed master plumber. While every effort is made to ensure these plans and specifications meet the plumbing & gas codes, the final approval for this project rests with the onsite inspection of the plumbing & gas systems by the certified plumbing inspector. Please refer to any attached comments with this letter regarding required changes or the need for additional plumbing.

For more information regarding this approval, please contact us on (501) 661-2642.

Sincerely,

A handwritten signature in red ink that reads "Erin Anderson".

Erin Anderson, State Plumbing Inspector
Plumbing & Natural Gas Section
Protective Health Codes

CC: Vacant, State Plumbing Inspector
Municipal Plumbing Inspector
Sanitarian

**NOTES
ATTACHED**

Arkansas Department of Health
4815 West Markham St. · Little Rock, AR 72205

HEALTHY.ARKANSAS.GOV

PLUMBING PLAN REVIEW

Project ID: 144470
Job Name: Bryant First Baptist Church
Street Location: 6715 Hwy 5 N.

PD#/ADH Area: ONLINE/Area IV
County: Saline
City/Township: Bryant

Project Comments and/or Needed Corrections

General Review Comment: Construction documents shall be of sufficient clarity to indicate the location, nature, and extent of the plumbing system per APC 106.3.1. Information provided only in general notes and specifications is not sufficient for plan review. All code-required elements shall be clearly shown on the plans.

Submitter states no food prep to be done in room 135 "Resource Kitchen". Approved with the stipulation of providing access to all air admittance valves.

2018 ARKANSAS STATE PLUMBING CODE

CHAPTER 9, SECTION 917

917.5 Access and ventilation. Access shall be provided to all air admittance valves. Such valves shall be installed in locations that allows air to enter the valve
