Colton Leonard <cleonard@cityofbryant.com>

Fwd: Fire approval

1 message

Truett Smith <tsmith@cityofbryant.com> Fri, Nov 3, 2023 at 9:54 AM
To: Colton Leonard <cleonard@cityofbryant.com>

This is the timeframe for this project. They did get a 6 month extension. That puts the deadline at 7/22/24.

---------- Forwarded message ---------
From: **Thomas Hammond** <thammond@cityofbryant.com>
Date: Fri, Nov 3, 2023 at 9:46 AM
Subject: Fwd: Fire approval
To: Truett Smith <tsmith@cityofbryant.com>

---------- Forwarded message ---------
From: **Shannon Nuckols** <slaureen.nuckols@gmail.com>
Date: Fri, Jul 22, 2022 at 1:41 PM
Subject: Re: Fire approval
To: Thomas Hammond <thammond@cityofbryant.com>

Thank you!

On Fri, Jul 22, 2022 at 1:27 PM Thomas Hammond <thammond@cityofbryant.com> wrote:

> Mrs. Nuckols,
>
> The purpose of this email is to confirm our conversation we had today, 7/22/22. The topic was using your living room area as a temporary classroom for children 3 to 6 years of age.
> Temporary in this instance would be a time period of no more than 18 months from the date of this email. In order to use the space discussed @ 4910 Springhill Rd. the following changes shall be made prior to approval.
>
> 1. The rear entrance door shall swing in the way of travel (outward) and be equipped with hardware requiring one motion to open.
> 2. ADA approved ramp shall be installed to service the rear entrance door. Ramp shall be a minimum of 44" in width. If the ramp is elevated it shall require a handrail on both sides.
> 3. Exits shall be marked with proper signage.
> 4. Fire Extinguisher shall be provided.
> 5. Room shall be integrated into existing daycare fire alarm system.
> 6. An Occupant Load of 15 school age (> 3) shall be assigned to space.
> 7. Remove the door going into the mudroom.
> 8. An inspection from the Fire Marshal and Code Enforcement shall prior to the issue of OC.
>
> On Fri, Jul 22, 2022 at 9:26 AM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:
>
> > Fire Marshall Hammond,
> > I just tried to call you and left a message.
> >
> > On Fri, Jul 22, 2022 at 9:18 AM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:
> > > Sorry- It is 501-381-4607. Ill try to call you also.
> > >
> > > On Fri, Jul 22, 2022 at 8:46 AM Thomas Hammond <thammond@cityofbryant.com> wrote:
> > > > Mrs. Nuckols,
> > > >
> > > > I have tried calling the # listed below a couple of times. It keeps stating that the call failed. Give me a call and we can discuss further.
> > > >
> > > > On Thu, Jul 21, 2022 at 12:12 PM Shannon Nuckols <slaureen.nuckols@gmail.com> wrote:
> > > > > Fire Marshall Hammond-
> > > > > Could you give me a call when you have a chance? Licensing came out today and said she would approve a space for us and wanted us to call fire department.
> > > > > --
> > > > > Shannon Nuckols, M.Ed
> > > > > Cornerstone Montessori Christian Academy
> > > > > Slaureen.nuckols@gmail.com
> > > > > https://www.cornerstone-montessori-christian.com
> > > > > 501-381-4607
> > > >
> > > > --
> > > > **Tommy Hammond**
> > > > **Battalion Chief**
> > > > **Fire Marshal**
> > > > **CFPE**
> > > > Bryant Fire Department

312 Roya Lane
Bryant, AR 72022
501-943-0964 Ext. 397 - Office
501-943-0982 - Fax

--
Shannon Nuckols, M.Ed
Cornerstone Montessori Christian Academy
Slaureen.nuckols@gmail.com
https://www.cornerstone-montessori-christian.com
501-381-4607

--
Shannon Nuckols, M.Ed
Cornerstone Montessori Christian Academy
Slaureen.nuckols@gmail.com
https://www.cornerstone-montessori-christian.com
501-381-4607

--
Tommy Hammond
Battalion Chief
Fire Marshal
CFPE
Bryant Fire Department
312 Roya Lane
Bryant, AR 72022
501-943-0964 Ext. 397 - Office
501-943-0982 - Fax

--
Shannon Nuckols, M.Ed
Cornerstone Montessori Christian Academy
Slaureen.nuckols@gmail.com
https://www.cornerstone-montessori-christian.com
501-381-4607

--

Tommy Hammond
Fire Marshal / Battalion Chief
City of Bryant

501-943-0964

thammond@cityofbryant.com

www.cityofbryant.com

312 Roya Lane, Bryant, AR 72022

--

Truett Smith, MPA, AICP, PCED
Community Development Director
City of Bryant

501-943-0309

tsmith@cityofbryant.com

www.cityofbryant.com

210 SW 3rd St, Bryant, AR 72022